



Lead in Drinking Water Report

Denville Board of Education
1 St Mary's Place
Denville, NJ 07624

July 2021

Prepared for:
Denville Board of
Education
1 St Mary's Place Denville,
NJ 07624

Prepared by:
New Wave Engineering, LLC
PO Box 4124
Wayne, New Jersey 07474



August 5, 2021

Mrs. Damaris Gurowsky
Business Administrator
Denville Board of Education
1 St Mary's Place
Denville, NJ 07624

Re: Lead in Drinking Water Services per NJAC 6A:26
Valleyview School, 320 Diamond Spring Road, Denville, NJ
Riverview School, 33 St Mary's Place, Denville, NJ
Riverview School Annex, 100 Route 46, Denville, NJ
Lakeview School, 44 Cooper Road, Denville, NJ

Dear Mrs. Gurowsky,

New Wave is pleased to submit this lead in drinking water report for the Denville Board of Education. This report details the methods and findings of the comprehensive lead in drinking water services as per New Jersey state regulations (amendments to N.J.A.C 6A:26 Educational Facilities) performed at the various schools in the Denville School District, located at the above referenced addresses between July 09, 2021 and July 29, 2021.

Best Regards,

Nadine Bello

Nadine Bello, MS, RPIH, CIEC, AST

[New Wave Engineering, LLC](#)

Table of Content

SUMMARY.....	Page 1
1.0 PROJECT BACKGROUND.....	Page 2
2.0 LEAD IN DRINKING WATER.....	Page 2
3.0 DRINKING WATER SAMPLING METHODOLOGY.....	Page 3
4.0 DRINKING WATER ANALYSIS RESULTS.....	Page 4
5.0 CONCLUSIONS & RECOMMENDATIONS.....	Page 7
6.0 DISCLAIMER.....	Page 7
7.0 CLOSING.....	Page 8

APPENDIX A: Chain of Custody and Lab Results

Executive Summary of Lead in Drinking Water Services

July 2021

New Wave Engineering was retained to conduct a first draw “lead in drinking water sampling” at the district’s school buildings located within the Denville Board of Education in July of 2021. Water samples were collected from designated drinking water outlets at the following schools:

All samples were collected according to the regulatory guidelines outlined in the amendments to the N.J.A.C. 6A:26: Educational Facilities (July 2016) and its supporting documentation.

- **Valleyview School**
- **Riverview School**
- **Riverview School Annex**
- **Lakeview School**

First draw sample results indicated that water sources sampled at locations from the schools, exhibited no lead levels above the Regulatory Action Level of .015mg/l, or its equivalent: 15ppb, **except** in four (4) samples: one (1) sample in the Riverview Annex and three (3) samples in the Valleyview School. All 4 sample areas that exceeded the action level of 15mg/l, or 15ppb, were sinks and *not* drinking water fountains, bottle fillers or bubblers. Subsequently, secondary Flush Samples were performed and three (3) re-tested sink areas were below the acceptable action level of .015mg/l or 15ppb, and *safe for use*. The one area slightly above the acceptable “action level” was the nurse’s sink in the Valleyview School. A recommendation was made to the district to install a filter to purify the water and reduce the lead levels and other contaminates. On August 8 the District installed a filtration system onto the nurse’s sink and established a protocol to monitor and replace the filter on a periodic basis.

1.0 PROJECT BACKGROUND

New Wave Engineering was contacted by the Denville Board of Education (the "Client") to perform lead in drinking water sampling to determine the lead content of drinking water from sources throughout the school facilities. Additionally, as per State regulations, New Wave was contracted to update a Quality Assurance Project Plan (QAPP) and a Sampling Plan (SP), including: a Drinking Water Outlet Inventory, Filter Inventory, and Outlet Location Schematic in conjunction with the District's Buildings and Grounds Director.

The purpose of lead in drinking water sampling is to determine if any sampled drinking water sources exhibit lead levels exceeding the Regulatory Action Level of 15 parts per billion (ppb) which may also be designated as: .015mg/l. Drinking water concentration points included: any water sources from which a student, staff, or faculty may reasonably drink or from which the water may be used for cooking or beverage preparation, including, but not limited to, water coolers/bubblers, kitchen faucets, Nurse's Office faucets, and Faculty/Staff lounges.

For further information on guidance protocols and Action Levels that were followed please refer to: The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools" and the Guidance Document from NJDEP Division of Water Supply and Geoscience — "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

2.0 LEAD IN DRINKING WATER

Lead is a toxic substance that can be harmful to human health. As compared to adults, children are more susceptible to the detrimental health effects of lead, as their nervous systems are not yet fully developed. Exposure to lead can occur in a variety of ways including through food, soil, deteriorating lead-based paint, and drinking water. Lead can leach into drinking water from plumbing materials such as pipes and solder, as well as brass plumbing fixtures. For this investigation, planning, preparation, methodology, sampling, and follow up actions were conducted according to the technical guidance provided by New Jersey following the adoption of amendments to N.J.A.C. 6A:26: "Educational Facilities, requiring the sampling of drinking water for Lead in Schools"

3.0 DRINKING WATER SAMPLING METHODOLOGY

New Wave collected drinking water samples from water outlets throughout each school building. At each collection point, New Wave filled a 250 milliliter (ml) wide-mouth high density polyethylene (HDPE) sample collection bottle from the designated water source. Samples were collected after the water in each building had not been used for at least 8 hours, but not more than 48 hours. The initial sample at each collection point represents the first draw sample. The first draw sample is representative of the water from the end point of the water source (i.e., the bubbler/bottle filler or tap).

A field blank using lead-free laboratory reagent water was also collected for each Facility during the sampling event to rule out contamination of samples during the collection and transportation process. All samples were recorded utilizing proper chain of custody documents and couriered to *Garden State Laboratory*, a New Jersey certified laboratory (NJ Lab ID #20044) located in Hillside, New Jersey for analysis via EPA method 200.80

During the initial sampling event on July 15, New Wave collected the following number of samples at each School Building:

Valleyview School

- 1) 1 Field Blank Sample
- 2) 12 first draw samples

Riverview School

- 1) 1 Field Blank Sample
- 2) 6 first draw samples

Riverview School Annex

- 1) 1 Field Blank Sample
- 2) 4 First Draw Sample

Lakeview School

- 1) 1 Field Blank Sample
- 2) 5 First Draw Sample

After receipt of the first draw sampling result and a secondary flush (i.e., second-draw), sampling was conducted to aid with the determination of the source of any lead contamination.

During the flush sampling event on July 29, 2021, New Wave collected the following number of samples:

Riverview School Annex:

- One Flush Sample- Faculty Sink

Valleyview School

- One Flush Sample - Nurse's Sink
- One Flush Sample - Media Office Sink
- One Flush Sample - Room C13 Sink

For a complete drinking water outlet inventory and sampling location diagram for each facility, please refer to the Sampling Plan, dated May 2017. Updates to this documentation can be found in the Field Log Book for each facility.

4.0 DRINKING WATER ANALYSIS RESULTS

The analytical “lead in drinking water results” for each first draw sample is listed in Tables below:

Table 1: Analytical Lead Results for First Draw Water Samples Collected from **Valleyview School** July 09, 2021

Sample I.D.	Type of Collection Point	Lead Concentration (mg/l)	Above Regulatory Action Level?
DEN-VV-21-1	BF -Hall by Office	< 1.00	No
DEN-VV-21-2	BF- Lunchroom	< 1.00	No
DEN-VV-21-3	Sink-Media Office	0.0199	Yes
DEN-VV-21-4	Sink-Life Study A	< 1.00	No
DEN-VV-21-5	Sink- Life Study B	< 1.00	No
DEN-VV-21-6	Sink- Life Study C	< 1.00	No
DEN-VV-21-7	Sink- Life Study D	0.0034	No
DEN-VV-21-8	BF-end of hall lower	< 1.00	No
DEN-VV-21-9	BF- C Wing	< 1.00	No
DEN-VV-21-10	Sink Room C-13	0.0292	Yes
DEN-VV-21-11	Sink- Nurse's Office	0.0484	Yes
DEN-VV-21-12	Sink- Faculty Room	0.0020	No
DEN-VV-21-13	FIELD BLANK	< 1.00	No

BF= Bottle Filler Station

Table 2: Analytical Lead Results for First Draw Water Samples
Collected from **Riverview School** taken on July 9, 2021

Sample ID.	Type of Collection Point	Lead Concentration (mg/l)	Above Regulatory Action Level?
DEN-R-21-1	BF- Hall by APR	<1.00	No
DEN-R-21-2	Sink- Kitchen	0.0014	No
DEN-R-21-3	BF-by Room 2	<1.00	No
DEN-R-21-4	Sink- Nurse's Office	0.0029	No
DEN-R-21-5	Sink- Faculty Room	0.0109	No
DEN-R-21-6	BF- by Room 26	<1.00	No
DEN-R-21-7	FIELD BLANK	<1.00	No

Table 3: Analytical Lead Results for First Draw water Samples Collected
from **Riverview School Annex** July 9, 2021

Sample LDs	Type of Collection Point	Lead Concentration (mg/l)	Above Regulatory Action Level?
DEN-RA-21-1	Sink- Nurse's Office	0.011	No
DEN-RA-21-2	BF by Office	<1.00	No
DEN-RA-21-3	BF by rear door	< 1.00	No
DEN-RA-21-4	Sink- Faculty Room	0.0359	Yes
DEN-RA-21-5	FIELD BLANK	< 1.00	No

Table 4: Analytical Lead Results for First Draw water Samples Collected from **Lakeview School** July 9, 2021

Sample LDs	Type of Collection Point	Lead Concentration (mg/l)	Above Regulatory Action Level?
DEN-L-21-1	BF- Main Hall	< 1.00	No
DEN-L-21-2	Sink -Nurse's Office	<1.00	No
DEN-L-21-3	Sink- Faculty Room	< 1.00	No
DEN-L-21-4	BF by Faculty Hall	< 1.00	No
DEN-L-21-5	BF by GYM	< 1.00	No
DEN-L-21-6	FIELDBLANK	< 1.00	No

All laboratory analytical results of first-draw samples were compared to the NJDEP's Regulatory Action Level of 15.5 ppb or .015 mg/l for lead. Analysis of lead in the first draw drinking water samples indicated that, at the time of the sampling event, one (1) sample collected from Riverview School Annex exhibited lead concentrations above the Action Level. Three (3) drinking water outlets from Valleyview School exhibited elevated lead levels above the Action Level

As per the State regulations, a "drinking water outlets exhibiting lead levels above the 15.5 ppb 05 .015 mg/l *Action Level* were immediately removed from drinking service and utilized as hand washing only. Flush sampling (second draw sampling) of the drinking water outlets with elevated lead levels were scheduled on July 29, 2021.

Table 5, below, illustrates the results of the flush sampling conducted on July 29, 2021.

Table 5: Analytical Lead Results for Second Draw Water Samples Collected from **The Riverview School Annex** and **Valleyview School** July 29, 2021

Sample ID	Type of Collection Point	Lead Concentration (mg/l)	First Draw Results
DEN-VV-21-03A	Sink-Media Office	0.0067	0.0199
DEN-VV-21-10A	Sink- Room C13	0.0019	0.0292
DEN-VV-21-11A	Sink- Nurse's Office	0.0257	0.0484
DEN-RA-21-4A	Sink Faculty	0.0099	0.0359

Based on these recommendations the Client chose to add a filtration system to the sink in the nurse's office at Valleyview School to purify the water and reduce any levels of particulates.

5.0 CONCLUSIONS & RECOMMENDATIONS

New Wave collected first draw samples from drinking water sources throughout the Denville Board of Education school facilities. First draw sample results indicated that a total of four (4) water samples *exceeded* the regulatory action level of 15 ppb or .015mg/l. Those water outlet sources were immediately taken out of service for drinking purposes or designated hand-washing only. Subsequent *Flush Sampling* was conducted and three (3) sinks levels decreased below the action level. These three sinks were reinstated as fully operable for drinking and hand washing. One remaining sink's re-test was slightly above the "action level" and therefore a filtration system was added to reduce the lead particulate levels. In conclusion of the comprehensive "lead in drinking water" services, New Wave offers the following recommendations:

- Continue to monitor lead in drinking water levels as part of a regular sampling and maintenance plan, per New Jersey State regulations.
- Implement an aerator cleaning maintenance program to prevent the build up of debris behind the aerator screen which may contribute to elevated lead levels.
- Enter all filter maintenance, aerator maintenance, plumbing repairs/changes and any other important information into the *Field Log Book* for each School.
- Use only cold water for food and beverage preparation, as hot water is more likely to contribute to the corrosion of plumbing materials and therefore may contain a greater level of water contaminants from the plumbing system.

6.0 Disclaimer

This investigation focused on lead in drinking water. No other heavy metals or additional contaminants were sampled for/or analyzed. Note: Lead concentrations in water can change as water continues to move through the water system.

Each sample taken was a "grab sample" and represents lead concentrations only at the specific time of collection and may vary based upon the water usage in the facility. Interpretation of these results is only valid if the facility is serviced by a municipal water supplier or water utility.

Our lead sampling event was in response to recent amendments to N.J.A.C. 6A:26i *Educational Facilities* dated July 13, 2016, which requires testing for lead in drinking water of public and charter school districts

The Lead Hazard Assessment has limitations with regards to identification of actual health and environmental issues. It is limited to only those items listed in the report and all items reflect conditions at the time of the assessment.

New Wave Engineering, LLC warrants only that the contents of this report constitute an informed discussion of the assessment at the subject property and is prepared exclusively for the above noted client. New Wave Engineering, LLC assumes no liability with regards to the use of this information or decisions which are made regarding the subject properties. It is at the discretion of the School District, given the results and information in this report, to use their own best judgment to determine any appropriate course of action.

7.0 Closing

The drinking water in the Denville Public Schools is below the action level of 15 ppb or .015 mg/l with the exception of the nurse's sink in the Valleyview School. The nurse's sink was equipped with a filtration system to reduce any lead particulates. It should also be noted that the secondary flush draw at the nurse's sink was reduced by almost half the lead particles from the first grab draw.

Thank you for utilizing New Wave to assist your District with this project. Please do not hesitate to call if you have any questions relating to this report or for any other environmental health and safety concerns.

APPENDIX A CHAIN OF CUSTODY AND LAB RESULTS



Garden State Laboratories, Inc.

Report Date: 07/27/2021

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Denville Board of Ed - NW
1 St. Mary's Place

Denville, NJ

Laboratory Director:

Attention: Damaris Gurowsky

Client Number: DEN03

Sample ID: Riverview Annex School 2
Mary's Place Denville Den Ra
21-1 Nurse Sink

Lab Sample ID: 210709038-01

Site: Collection Date/Time: 07/09/2021 05:57

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.0114 mg/l	0.015	0.00100	6E-05	20044	07/14/21 11:08	

Sample ID: Riverview Annex School 2
Mary's Place Denville Den Ra
21-2 BF by Office

Lab Sample ID: 210709038-02

Site: Collection Date/Time: 07/09/2021 05:58

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 11:12	

Sample ID: Riverview Annex School 2
Mary's Place Denville Den Ra
21-3 BF by rear

Lab Sample ID: 210709038-03

Site: Collection Date/Time: 07/09/2021 06:00

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 11:16	



Sample ID: Riverview Annex School 2 Lab Sample ID: 210709038-04
 Mary's Place Denville Den Ra
 21-4 Faculty Sink

Site: Collection Date/Time: 07/09/2021 06:01

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.0359 mg/l	0.015	0.00100	6E-05	20044	07/14/21 11:27	

Sample ID: Riverview Annex School 2 Lab Sample ID: 210709038-05
 Mary's Place Denville Den Ra
 21-5 Field Blank

Site: Collection Date/Time: 07/09/2021 05:55

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 11:31	

Sample ID: Lakeview School - 44 Cooper Lab Sample ID: 210709038-06
 Ave Denville NJ DEN L -21-
 1 Main Hall BF

Site: Collection Date/Time: 07/09/2021 06:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 11:35	

Sample ID: Lakeview School - 44 Cooper Lab Sample ID: 210709038-07
 Ave Denville NJ DEN L -21-
 2 Nurses Sink

Site: Collection Date/Time: 07/09/2021 06:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 11:46	

Sample ID: Lakeview School - 44 Cooper Lab Sample ID: 210709038-08
 Ave Denville NJ DEN L -21-
 3 Faculty Sink

Site: Collection Date/Time: 07/09/2021 06:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 11:50	



Sample ID: Lakeview School - 44 Cooper Ave Denville NJ DEN L -21-4 By Faculty BF Lab Sample ID: 210709038-09

Site: Collection Date/Time: 07/09/2021 06:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 11:54	

Sample ID: Lakeview School - 44 Cooper Ave Denville NJ DEN L -21-5 By Gym BF Lab Sample ID: 210709038-10

Site: Collection Date/Time: 07/09/2021 06:22

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 11:57	

Sample ID: Lakeview School - 44 Cooper Ave Denville NJ DEN L -21-6 Field Blank Lab Sample ID: 210709038-11

Site: Collection Date/Time: 07/09/2021 06:15

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 12:01	

Sample ID: Valleyview School - 320 Diamond Spring Rd Denville DEN V 21-1 BF Hall by Office Lab Sample ID: 210709038-12

Site: Collection Date/Time: 07/09/2021 05:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 12:05	



Sample ID: Valleyview School - 320 Lab Sample ID: 210709038-13
 Diamond Spring Rd Denville
 DEN V 21-2 Lunchroom BF

Site: Collection Date/Time: 07/09/2021 05:22

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/14/21 12:09	

Sample ID: Valleyview School - 320 Lab Sample ID: 210709038-14
 Diamond Spring Rd Denville
 DEN V 21-3 Media Off Sink

Site: Collection Date/Time: 07/09/2021 05:24

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.0199 mg/l	0.015	0.00100	6E-05	20044	07/14/21 12:12	

Sample ID: Valleyview School - 320 Lab Sample ID: 210709038-15
 Diamond Spring Rd Denville
 DEN V 21-4 Lifestudy Sink A

Site: Collection Date/Time: 07/09/2021 05:25

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00118 mg/l	0.015	0.00100	6E-05	20044	07/14/21 12:16	

Sample ID: Valleyview School - 320 Lab Sample ID: 210709038-16
 Diamond Spring Rd Denville
 DEN V 21-5 Lifestudy Sink B

Site: Collection Date/Time: 07/09/2021 05:25

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00245 mg/l	0.015	0.00100	6E-05	20044	07/15/21 09:48	

Sample ID: Valleyview School - 320 Lab Sample ID: 210709038-17
 Diamond Spring Rd Denville
 DEN V 21-6 Life Study Sink C

Site: Collection Date/Time: 07/09/2021 05:26

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00779 mg/l	0.015	0.00100	6E-05	20044	07/15/21 09:56	



Sample ID: Valleyview School - 320
Diamond Spring Rd Denville
DEN V 21-7 Life Study Sink
D

Lab Sample ID: 210709038-18

Site: Collection Date/Time: 07/09/2021 05:26

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00342 mg/l	0.015	0.00100	6E-05	20044	07/15/21 10:07	

Sample ID: Valleyview School - 320
Diamond Spring Rd Denville
DEN V 21-8 BF end of
Hallway

Lab Sample ID: 210709038-19

Site: Collection Date/Time: 07/09/2021 05:28

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/15/21 10:11	

Sample ID: Valleyview School - 320
Diamond Spring Rd Denville
DEN V 21-9 BF C Wing

Lab Sample ID: 210709038-20

Site: Collection Date/Time: 07/09/2021 05:29

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/15/21 10:15	

Sample ID: Valleyview School - 320
Diamond Spring Rd Denville
DEN V 21-10 C 13 Sink

Lab Sample ID: 210709038-21

Site: Collection Date/Time: 07/09/2021 05:31

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.0292 mg/l	0.015	0.00100	6E-05	20044	07/15/21 10:26	

Sample ID: Valleyview School - 320
Diamond Spring Rd Denville
DEN V 21-11 Nurse Sink

Lab Sample ID: 210709038-22

Site: Collection Date/Time: 07/09/2021 05:31

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	2	0.0484 mg/l	0.015	0.00200	0.00012	20044	07/16/21 11:21	



Sample ID: Valleyview School - 320
Diamond Spring Rd Denville
DEN V 21-12 Faculty Sink

Lab Sample ID: 210709038-23

Site: Collection Date/Time: 07/09/2021 05:33

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00200 mg/l	0.015	0.00100	6E-05	20044	07/15/21 10:37	

Sample ID: Valleyview School - 320
Diamond Spring Rd Denville
DEN V 21-13 Field Blank

Lab Sample ID: 210709038-24

Site: Collection Date/Time: 07/09/2021 05:20

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/15/21 10:41	

Sample ID: Riverview School - 33 St.
Mary's Place Denville Den R
-21-1 APR - Hall BF

Lab Sample ID: 210709038-25

Site: Collection Date/Time: 07/09/2021 05:45

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/15/21 10:45	

Sample ID: Riverview School - 33 St.
Mary's Place Denville Den R
-21-2 Kitchen Sink

Lab Sample ID: 210709038-26

Site: Collection Date/Time: 07/09/2021 05:46

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00142 mg/l	0.015	0.00100	6E-05	20044	07/15/21 10:49	

Sample ID: Riverview School - 33 St.
Mary's Place Denville Den R
-21-3 BF - By Rm 2

Lab Sample ID: 210709038-27

Site: Collection Date/Time: 07/09/2021 05:47

Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/15/21 10:52	



Sample ID: Riverview School - 33 St. Lab Sample ID: 210709038-28
 Mary's Place Denville Den R
 -21-4 Nurse Sink
 Site: Collection Date/Time: 07/09/2021 05:48
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00297 mg/l	0.015	0.00100	6E-05	20044	07/15/21 10:56	

Sample ID: Riverview School - 33 St. Lab Sample ID: 210709038-29
 Mary's Place Denville Den R
 -21-5 Faculty Sink
 Site: Collection Date/Time: 07/09/2021 05:47
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.0109 mg/l	0.015	0.00100	6E-05	20044	07/15/21 11:00	

Sample ID: Riverview School - 33 St. Lab Sample ID: 210709038-30
 Mary's Place Denville Den R
 -21-6 Bottler Filler by 26
 Site: Collection Date/Time: 07/09/2021 05:45
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/15/21 11:15	

Sample ID: Riverview School - 33 St. Lab Sample ID: 210709038-31
 Mary's Place Denville Den R
 -21-7 Field Blank
 Site: Collection Date/Time: 07/09/2021 05:45
 Matrix: Potable water Sample Type: Grab

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	< 0.00100 mg/l	0.015	0.00100	6E-05	20044	07/15/21 09:52	

DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
 The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
 Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.



Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

Name: Denville Bd of Education Contact/Authorized by: DAMARIS GURDOWSKY
 Mailing Address: 1 ST. MARY'S PLACE Phone: 973-983-6530 X 3093
 City/State/Zip: Denville, NJ 07834 Email: DGurdowsky@Denville.org

SAMPLE INFORMATION

SAMPLE TYPE: _____
 SAMPLE LOCATION: Riverview School - 33 St. Mary's Place, Denville, NJ

Grab Comp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)	Total Pages
		Date	Time	AM PM		
	DENR-21-6 Bottle Filler Lab	07/09/21	5:45	X	LEAD	
	DENR-21-7 Field Blank	07/09/21	5:45	X	LEAD	

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: Standard Rush (if RUSH REQUESTED) Rush Due by: 4 WEEK TURNAROUND
 REPORT FORMAT: Standard Report Other/Specify: _____ PWS ID#: _____

SEND TO: _____
 DATE/TIME: _____
 METHOD OF SHIPMENT: _____

Amount Due: \$ _____
 Payment Method: Credit Card Type: _____ Check # _____ Other: See Quote
 Note: Please email/send results to: New wave ENGINEERING, PO Box 4124 WAYNE NJ
email: JERNALTD@aol.com / JERRY @ new wave environmental.com

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY BELLO / MAX MAZZA Signature: [Signature] Date/Time: 07/09/2021
 Client/Client's Representative (PRINT): _____ Signature: _____ Date/Time: 07/09/2021
 1. Received/Relinquished by (PRINT): C. Bello Signature: [Signature] Date/Time: 07/09/2021
 2. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: 7/16/21 14:08

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TN1, NY Dept. of Health, NJDEP-TN1, NY Dept. of Health, NJDEP-TN1, NY Dept. of Health #11550 and PADEP #68-03660

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

FOR SAMPLE RECEIVING USE ONLY
 DATE/TIME/TEMP. REC'D AT LAB:
7/9/21 13:57 25.82

Page _____ of _____

GSL CLIENT # DEN03

MICRO # _____

CHEM. # 21090 21070908-031

SAMPLE REC'D BY: _____

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

CONTAINER INFORMATION			
No.	Type*	Size	Pres.*
	P	250	38-30
	P	250	38-31

SUBCONTRACTED WORK

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Denville Bd of Ed Contact/Authorized by: DAMARIS GUROWSKY
 Mailing Address: 1 ST. MARY'S PLACE Phone: 973-983-6530 X3093
 City/State/Zip: Denville, New Jersey 07834 Email: DGUROWSKY@Denville.ORG

SAMPLE INFORMATION

SAMPLE TYPE: ORG
 SAMPLE LOCATION: RIVERVIEW SCHOOL - 33 ST. MARY'S PLACE, Denville

Grab Comp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				
		Date	Time	AM	PM	List attached	Total Pages	No.	Type*	Size	Pres.*
	DENR-21-1 APR - Hall BF	07/09/21	5:45	X		LEAD			P	250	38-25
	DENR-21-2 Kitchen Sink	07/09/21	5:46	X		LEAD			P	250	38-24
	DENR-21-3 BF - bylrm 2	07/09/21	5:47	X		LEAD			P	250	38-27
	DENR-21-4 Nurse sink	07/09/21	5:48	X		LEAD			P	250	38-28
	DENR-21-5 Faculty sink	07/09/21	5:47	X		LEAD			P	250	38-29

Container type: P = Plastic G = Glass I = Sterile Tin V = Vial Other/Specify: _____
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: Standard Rush (If RUSH REQUESTED) Rush Due by: 4 WEEK TURNAROUND
 REPORT FORMAT: Standard Report Other/Specify: _____
 PWS ID#: _____

FOR SAMPLE RECEIVING USE ONLY
 DATE/TIME/TEMP. REC'D AT LAB: 7/9/21 13:59 25.8
 Page _____ of _____
 GSL CLIENT # DEN103
 MICRO # _____
 CHEM. # 210709088-25-29
 SAMPLE REC'D BY: _____
 GSL FIELD SAMPLER/PICK-UP
 PICK-UP AT DROP OFF LOCATION
 DELIVERED BY CLIENT

SEND TO: _____
 DATE/TIME: _____
 METHOD OF SHIPMENT: _____
 Amount Due: \$ _____
 Rush Fee: \$ _____
 Check # _____
 Other: See Quote

Payment Method: Credit Card Type: _____
 Note: Please send email report to: NEWWAVE ENGINEERING, PO Box 4184 WAYNE NJ 07474
email: JERNALID@GOL.COM/JERRY@NEWWAVEENVIRONMENTAL.COM

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
 PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY BELLO/MAXX MAZZA Signature: [Signature] Date/Time: 07/09/2021
 Client/Client's Representative (PRINT): _____ Signature: _____ Date/Time: _____
 1. Received/Relinquished by (PRINT): _____ Signature: [Signature] Date/Time: 07/09/2021
 2. Received/Relinquished by (PRINT): _____ Signature: [Signature] Date/Time: 7/9/21 14:10

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TNL, NY Dept. of Health #11550 and PADEP #68-0360

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gsllabs.com info@gsllabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Denville Bd of Education Contact/Authorized by: DAMARIS GUROWSKY
 Mailing Address: 1 St MARY'S Place Phone: 973-983-6538
 City/State/Zip: Denville, NJ 07834 Email: dgurowsky@denville.org

SAMPLE INFORMATION

SAMPLE TYPE: _____
 SAMPLE LOCATION: VALLEY VIEW School 300 Diamond Springs Rd. Denville

Grab Comp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)	Total Pages
		Date	Time	AM PM		
	DENV 21-11 nurse sink	07/09/21		X	Lead	1
	DENV 21-12 Faculty sink	07/09/21		X	Lead	1
	DENV 21-13 Field Blank	07/09/21		X	Lead	1

TURNAROUND TIME: Standard Rush (if RUSH REQUESTED) Rush Due by: 4 WEEK TURNAROUND
 REPORT FORMAT: Standard Report Other/Specify: _____
 PWS ID#: _____

FOR SAMPLE RECEIVING USE ONLY
 DATE/TIME/TEMP. REC'D AT LAB: 7/19/21 13:59 25.8
 Page _____ of _____
 GSL CLIENT # DENV03
 MICRO # _____
 CHEM. # 210709038-20-24
 SAMP LER REC'D BY: _____
 GSL FIELD SAMPLER/PICK-UP
 PICK-UP AT DROP OFF LOCATION
 DELIVERED BY CLIENT

CONTAINER INFORMATION

No.	Type*	Size	Pres.*
	P	250	382
	P	250	382
	P	250	382

AMOUNT DUE: \$ _____
 RUSH FEE: \$ _____
 CHECK # _____
 PAYMENT METHOD: Composite Fee: \$ _____
 Credit Card Type: _____
 OTHER: See Quote

NOTICE: Please send email to: New Wave Engineering PO Box 4124 Wayne, NJ 07474
email: JERNALTD@goi.com / JERY@newwaveenvironmental.com

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
 PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello / MAXX MAZZA Signature: [Signature] Date/Time: 07/09/2021
 Client/Client's Representative (PRINT): _____ Signature: _____ Date/Time: 07/09/2021
 1. Received/Relinquished by (PRINT): [Signature] Signature: _____ Date/Time: 07/09/2021
 2. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: 7/19/21 14:00

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED
 CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TNL NY Dept. of Health #11550 and PADEP #68-03660

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044

Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

Name: Denville Rd of ED
 Mailing Address: 1 ST. MARY'S place
 City/State/Zip: Denville, NJ
 Contact/Authorized by: Damaris Gurowsky
 Phone: 973-983-630X 3093
 Email: DGurowsky@Denville.org

SAMPLE INFORMATION

SAMPLE TYPE: _____
 SAMPLE LOCATION: Valleyview school 320 Diamond Spring Rd. Denville

Grab Comp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				
		Date	Time	AM	PM	List attached	Total Pages	No.	Type*	Size	Pres.*
	<u>Den Val-6 W/Study Sink</u>	<u>07/09/24</u>			<u>X</u>				<u>P</u>	<u>250</u>	<u>38-17</u>
	<u>Den Val-7 W/Study Sink</u>	<u>07/09/24</u>			<u>X</u>				<u>P</u>	<u>250</u>	<u>38-18</u>
	<u>Den Val-8 BF end of Hall way</u>	<u>07/09/24</u>			<u>X</u>				<u>P</u>	<u>250</u>	<u>38-19</u>
	<u>Den Val-9 BF Cwina</u>	<u>07/09/24</u>			<u>X</u>				<u>P</u>	<u>250</u>	<u>38-20</u>
	<u>Den Val-10 C13 Sink</u>	<u>07/09/24</u>			<u>Y</u>				<u>P</u>	<u>250</u>	<u>38-21</u>

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 → Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: Standard Rush
 REPORT FORMAT: Standard Report Other/Specify: _____
 PWS ID#: _____

IF RUSH REQUESTED, Rush Due by: 4 WEEK TURNAROUND

Amount Due: \$ _____
 Rush Fee: \$ _____
 Other: See Quote

Payment Method: Credit Card Type: _____
 Composite Fee: \$ _____
 Check # _____

Subcontracted Work: SUBCONTRACTED WORK

DATE/TIME: _____
 METHOD OF SHIPMENT: _____

FOR SAMPLE RECEIVING USE ONLY
 DATE/TIME/TEMP. REC'D AT LAB:
7/9/24 10:59 25.8

Page _____ of _____
 GSL CLIENT # DEN03
 MICRO # _____
 CHEM. # 210709038-17-21
 SAMPLE REC'D BY: _____
 GSL FIELD SAMPLER/PICK-UP
 PICK-UP AT DROP OFF LOCATION
 DELIVERED BY CLIENT

Sampled by (PRINT): JERRY BELLO / MAXX MAZZA Signature: [Signature] Date/Time: 07/09/2024
 Client/Client's Representative (PRINT): _____ Signature: _____ Date/Time: _____
 1. Received/Relinquished by (PRINT): _____ Signature: [Signature] Date/Time: 07/09/2024
 2. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: 7/9/24 15:00

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME
 SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

Note: Please send email to: NEW WAVE ENGINEERING PO BOX 4124 WAYNE NJ 07474
 email: JERNALTD@aol.com / JERRY@NEWWAVEENVIRONMENTAL.COM

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TNI, NY Dept. of Health #11550 and PADEP #68-03660

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Denville Bd of Education Contact/Authorized by: Damaris Gurovsky
 Mailing Address: 1 ST. MARY'S PLACE Phone: 973-983-6530 X 3093
 City/State/Zip: Denville, NJ Email: DGurovsky@denville.org

SAMPLE INFORMATION

SAMPLE TYPE: _____
 SAMPLE LOCATION: VALLEYVIEW SCHOOL-320 DIAMOND SPRING RD Denville

Grab Comp	SAMPLE ID	SAMPLE COLLECTION		ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
		Date	Time	AM	PM	No.	Type*	Size	Pres.*
	DENV 21-1 BF HALL by OFFICE	07/09/21	5:20	X			P	250	3812
	DENV 21-2 LUNCH ROOM BF	07/09/21	5:22	X			P	250	3813
	DENV 21-3 MEDIA OFF SINK	07/09/21	5:24	X			P	250	3814
	DENV 21-4 LIFE STUDY SINK A	07/09/21	5:25	X			P	250	3815
	DENV 21-5 LIFE STUDY SINK B	07/09/21	5:25	X			P	250	3816

*Container Type: P = Plastic G = Glass T = Sterile Thio V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Coated Other/Specify: _____

TURNAROUND TIME: Standard Rush (if RUSH REQUESTED) Rush Due by: 4 WEEK TURN AROUND
 REPORT FORMAT: Standard Report Other/Specify: _____
 PWS ID#: _____

PAYMENT INFORMATION
 Sampling/Pick-up Fee: \$ Composite Fee: \$ Check # _____
 Credit Card Type: _____
 Amount Due: \$ _____
 Rush Fee: \$ _____

Note: Please email/send results to New Wave Engineering - PO. Box 4124 WAYNE NJ 07474
email: JERNALTD@aol.com / JERLEY@newwaveenviromental.com
SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
PLEASE PRINT YOUR NAME LEGIBLY, USE FULL-LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY BELLO / MAXY MAZZA Signature: [Signature] Date/Time: 07/09/2021
 Client/Client's Representative (PRINT): _____ Signature: _____ Date/Time: _____
 1. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: _____
 2. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: 7/9/21 14:00

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TNJ, NY Dept. of Health #11550 and PADEP #68-03690

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Denville Bd of ED Contact/Authorized by: DAMARIS GURROWSKY
 Mailing Address: 1 ST. MARY'S PLAZA Phone: 973-983-6530 X 3093
 City/State/Zip: DENVILLE, NJ 07834 Email: DGURROWSKY@DENVILLE.ORG

SAMPLE INFORMATION

SAMPLE TYPE: _____
 SAMPLE LOCATION: LAKEVIEW SCHOOL 44 COOPER RD DENVILLE NJ

Grab Comp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)
		Date	Time	AM PM	
	DEN21-6-Field Blank	07/09/21	6:15	X	Lead

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Tm = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: Standard Rush (IF RUSH REQUESTED, Rush Due by: 4 WEEK TURNAROUND)

REPORT FORMAT: Standard Report Other/Specify: _____

PWS ID#: _____

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ _____ Composite Fee: \$ _____ Rush Fee: \$ _____
 Payment Method: Credit Card Type: _____ Check # _____ Other: See Quote

Note: Please email/send results to: NEW WAVE ENGINEERING- PO BOX 4124 WAYNE NJ
email: JERVALTO@aol.com / JERRY@NEWWAVEENVIRONMENTAL.COM

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY BELLO / MAXX MAZZA Signature: [Signature] Date/Time: 07/09/2021
 Client/Client's Representative (PRINT): _____ Signature: _____ Date/Time: 07/09/2021
 1. Received/Relinquished by (PRINT): _____ Signature: [Signature] Date/Time: 07/09/2021
 2. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: 7/9/21 14:0

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TNI, NY Dept. of Health #11550 and PADEP #68-09680

FOR SAMPLE RECEIVING USE ONLY
 DATE/TIME/TEMP. REC'D AT LAB: 7/9/21 13:59 45.82
 Page _____ of _____
 GSL CLIENT # DEN03
 MICRO # _____
 CHEM. # 210709038-11
 SAMPLE REC'D BY: _____
 GSL FIELD SAMPLER/PICK-UP
 PICK-UP AT DROP OFF LOCATION
 DELIVERED BY CLIENT

CONTAINER INFORMATION
 No. Type* Size Pres.#
 38-11
 SUBCONTRACTED WORK
 SEND TO: _____
 DATE/TIME: _____
 METHOD OF SHIPMENT: _____

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Denville Bd of Ed Contact/Authorized by: Damaris Burrowsky
 Mailing Address: 1 St. Mary's place Phone: 973-983-6530 X3093
 City/State/Zip: Denville, New Jersey 07834 Email: DBurrowsky@Denville.org

SAMPLE INFORMATION

SAMPLE TYPE: _____
 SAMPLE LOCATION: LAKEVIEW School - 44 Cooper Ave Denville, NJ.

Grab Comp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION			
		Date	Time	AM PM	List attached	Total Pages	No.	Type*	Size	Pres.*
	DENVL2A1-1 MAIN HALL BF	07/09/21	6:15	X	<input type="checkbox"/>	Lead		P	250	38-01
	DENVL2A1-2 NURSC'S SINK	07/09/21	6:20	X	<input type="checkbox"/>	Lead		P	250	38-07
	DENVL2A1-3 Faculty SINK	07/09/21	6:20	X	<input type="checkbox"/>	Lead		P	250	38-08
	DENVL2A1-4 BY Faculty BF	07/09/21	6:20	X	<input type="checkbox"/>	Lead		P	250	38-09
	DENVL2A1-5 BY Gym BF	07/09/21	6:22	X	<input type="checkbox"/>	Lead		P	250	38-10

*Container Type: P = Plastic G = Glass A = Amber Glass V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: Standard Rush (IF RUSH REQUESTED) Rush Due by: 4 WEEK THEN ARBUND
 REPORT FORMAT: Standard Report Other/Specify: _____
 PWS ID#: _____
 METHOD OF SHIPMENT: _____

FOR SAMPLE RECEIVING USE ONLY
 DATE/TIME/TEMP. REC'D AT LAB: 7/9/21 13:59 25.8°C
 Page _____ of _____
 GSL CLIENT # DENV03
 MICRO # _____
 CHEM. # 210709038-01670
 SAMPLE REC'D BY: _____
 GSL FIELD SAMPLER/PICK-UP
 PICK-UP AT DROP OFF LOCATION
 DELIVERED BY CLIENT

AMOUNT DUE: \$ _____
 RUSH FEE: \$ _____
 COMPOSITE FEE: \$ _____
 CREDIT CARD TYPE: _____
 PAYMENT INFORMATION

NOTE: PLEASE email/SEND RESULTS TO: NEW WAVE ENGINEERING PO BOX 4124 WAYNE NJ.
email: JERNALTD@aol.com / SEREX@newwaveenvironmental.com
 SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION
 PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY Bello/ MAXX MAZZA Signature: [Signature] Date/Time: 07/09/2021
 Client/Client's Representative (PRINT): _____ Signature: _____ Date/Time: 07/09/2021
 1. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: 07/09/2021
 2. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: 7/9/21 13:59

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TNL NY Dept. of Health #11550 and PADEP #68-05680

Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop-off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Denville Bd of Ed. Contact/Authorized by: DAMARIS FURROWSKY
 Mailing Address: 1 ST. MARY'S PLACE Phone: 973-983-6530 - X3093
 City/State/Zip: DENVILLE, NEW JERSEY Email: DGURROWSKY@DENVILLE.ORG

SAMPLE INFORMATION

SAMPLE TYPE: _____
 SAMPLE LOCATION: RIVERVIEW ANNEX SCHOOL - 2 ST. MARY'S PLACE, DENVILLE

Grab Comp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION
		Date	Time	AM PM		
	DENRA21-1-NURSE SINK	07/09/21	5:57	X	LEAD	P 250 3801
	DENRA21-2 BF by office	07/09/21	5:58	X	LEAD	P 250 3803
	DENRA21-3 BF by rear	07/09/21	6:00	X	LEAD	P 250 3803
	DENRA21-4 Faculty SINK	07/09/21	6:01	X	LEAD	P 250 3804
	DENRA21-5 Field Blank	07/09/21	5:55	X	LEAD	P 250 3805

*Container Type: P = Plastic G = Glass I = Amber Glass V = Vial Other/Specify: _____
 *Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiocyanate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: Standard Rush (if RUSH REQUESTED) Rush Due by: 4 WEEK TURN AROUND

REPORT FORMAT: Standard Report Other/Specify: _____

PAYMENT INFORMATION: Standard Report + E2 PWS ID#: _____

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$

Payment Method: Credit Card Type: _____ Check # _____ Other: See Quote

Note: Please email/send results to: NEW WAVE ENGINEERING, PO BOX 4124, WAYNE NJ 07474
email: JERNALTO@aol.com / JERRY@newwaveenvironmental.com

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JERRY BELLO / MAXY MAZZA Signature: [Signature] Date/Time: 07/09/2021
 Client/Client's Representative (PRINT): _____ Signature: _____ Date/Time: 07/09/2021
 1. Received/Relinquished by (PRINT): C. Bracco Signature: [Signature] Date/Time: 07/09/2021
 2. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: 1/9/21 4:00

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-TL, NJ Dept. of Health, NJDEP-TL, NJ Dept. of Health #11550 and PADEP #68-08680

FOR SAMPLE RECEIVING USE ONLY
 DATE/TIME/TEMP. REC'D AT LAB:
7/9/21 13:59 25.82
 (NDEP)

Page _____ of _____

GSL CLIENT # DEN03

MICRO # _____

CHEM. # 210709038-01-05

SAMPLE REC'D BY: _____

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

SUBCONTRACTED WORK

SEND TO: _____

DATE/TIME: _____

METHOD OF SHIPMENT: _____



Garden State Laboratories, Inc.

Report Date: 08/10/2021

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Denville Board of Ed - NW
1 St. Mary's Place

Denville, NJ

Laboratory Director:

Attention: Damaris Gurowsky

Client Number: DEN03

Sample ID: DenV-21-11A-Nurse's Sink

Lab Sample ID: 210729069-01

Site:

Collection Date/Time: 07/29/2021 06:45

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.0257 mg/l	0.015	0.00100	6E-05	20044	08/03/21 09:10	

*DF=Dilution factor, <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*



Garden State Laboratories, Inc.



Garden State Laboratories, Inc.

Report Date: 08/10/2021

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Denville Board of Ed - NW
1 St. Mary's Place

Denville, NJ

Laboratory Director:

Attention: Damaris Gurowsky

Client Number: DEN03

Sample ID: DenV-21-3A-Media Sink

Lab Sample ID: 210729069-02

Site:

Collection Date/Time: 07/29/2021 06:46

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00676 mg/l	0.015	0.00100	6E-05	20044	08/03/21 09:21	

*DF=Dilution factor; <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*





Garden State Laboratories, Inc.

Report Date: 08/10/2021

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gsllabs.com
Internet: www.gsllabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Denville Board of Ed - NW
1 St. Mary's Place

Denville, NJ

Laboratory Director:

Attention: Damaris Gurowsky

Client Number: DEN03

Sample ID: DenV-21-10A-Rm. C13 Sink

Lab Sample ID: 210729069-03

Site:

Collection Date/Time: 07/29/2021 06:46

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00199 mg/l	0.015	0.00100	6E-05	20044	08/03/21 09:25	

DF=Dilution factor; <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.





Garden State Laboratories, Inc.

Report Date: 08/10/2021

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A. Laboratory Manager

For: Denville Board of Ed - NW
1 St. Mary's Place

Denville, NJ

Laboratory Director:

Attention: Damaris Gurowsky

Client Number: DEN03

Sample ID: DenRA-21-4A-Faculty Sink

Lab Sample ID: 210729069-04

Site:

Collection Date/Time: 07/29/2021 07:10

Analyte	Method	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.8	1	0.00996 mg/l	0.015	0.00100	6E-05	20044	08/03/21 09:29	

*DF=Dilution factor; <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit and MDL=Method Detection Limit.
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with the most current Field Sampling Plan GSL.FS.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*



Garden State Laboratories, Inc.

Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044
 Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Denville Bd of Education Contact/Authorized by: Damaris Gironowsky
 Mailing Address: 1 St. Mary's Place Phone: 973-983-6530 x3093
 City/State/Zip: Denville NJ 07834 Email: JERNALTD@aol.com

SAMPLE INFORMATION

SAMPLE TYPE: GRAB

SAMPLE LOCATION: Denville Valleyview/Riverview Annex

Grab Comp	SAMPLE ID	SAMPLE COLLECTION			ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				
		Date	Time	AM PM	List attached	Total Pages	No.	Type*	Size	Pres.*	
X	DENV-21-11A-nurse's sink	07/29/21	6:45	X	<input type="checkbox"/>	LEAD - FIRST DRAW	069-01	1	P	250ml	A
X	DENV-21-3A-media sink	07/29/21	6:46	X	<input type="checkbox"/>	LEAD FIRST DRAW	069-02	1	P	250ml	A
X	DENV-21-10A-Rm C13-Sink	07/29/21	6:46	X	<input type="checkbox"/>	LEAD FIRST DRAW	069-03	1	P	250ml	A
X	DENV-21-14A-Faculty sink	07/29/21	7:10	X	<input type="checkbox"/>	LEAD FIRST DRAW	069-04	1	P	250ml	A

*Container Type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: _____
 ⇒ Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Thiosulfate H = Ascorbic Acid I = Cooled Other/Specify: _____

TURNAROUND TIME: Standard Rush (IF RUSH REQUESTED) Rush Due by: ASAP
 REPORT FORMAT: Standard Report Other/Specify: _____
 PWS ID#: _____

PAYMENT INFORMATION

Sampling/Pick-up Fee: \$ Composite Fee: \$ Rush Fee: \$ Amount Due: \$
 Payment Method: Credit Card Type: Check # Other: See Quote

Note:

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): JEREMY BELLO Signature: _____ Date/Time: 7/29/21 7:13 AM
 Client/Client's Representative (PRINT): MARY MAZZA Signature: _____ Date/Time: _____
 1. Received/Relinquished by (PRINT): _____ Signature: _____ Date/Time: _____
 2. Received/Relinquished by (PRINT): D. Reiner Signature: _____ Date/Time: 7/29/21 14:00

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
 Main Lab certified by NJ Dept. of Health, NJDEP-THL, NY Dept. of Health #11550 and PADEP #68-03650

